


# T E S T C E R T I F I C A T E

BT-23-03-22-02

**Product:** SAMBA/KENDO bamboo decking board  
(illustration provided by the client)

**Supplier:** FORESTIA Group – FELIXWOOD<sup>®</sup>  
2, rue de la Carnoy  
59130 LAMBERSART, FRANCE



**Order:** Determination of durability against wood destroying basidiomycete fungi in accordance with EN 350:2016 and EN 113-2:2020 after leaching according to EN 84:2020

**Test report:** 2222053 of 21 March 2023

**Test details:** Each 20 specimens were tested using three test fungi (*Coniophora puteana*, *Pleurotus ostreatus* and *Trametes (*Coriolus*) versicolor*).

**Test results:** The product is assigned to durability class 1 (very durable) according to EN 350:2016 classification.

Place, date of issue: Dresden, 22 March 2023

Date of expiry: 20 March 2028

Head of laboratory



Engineer in charge